


## Quantum University, Roorkee



7.1.2	<b>The Institution has facilities for alternate sources of energy and energy conservation measures</b>
-------	--

**Permission document for connecting to the grid from the Government/ Electricity authority.**

  
Registrar  
Quantum University

# Sealing Certificate, ETD, Roorkee

BOOK No. 16		Sealing Certificate ETD, Roorkee New/Check/Replacement/Checking		PAGE No. 20	
Consumer Name & Address: <u>M/S. L.M.D Education Research Foundation Institute</u>					
Voltage Supply: <u>11 KV</u>		Reference:		Sub-Station Name: <u>Raipur</u>	
Sanction Load: <u>250 KVA</u>		S/C No: <u>8HOK00005228</u>		Dated: <u>08/05/23</u>	
Feeder Name: <u>Quantum Reader</u>					
Make	Detail of Old Meter	Detail of New Meter	Modem/SIM/Seal Remark		
Serial No.	<u>22000733</u>	<u>22000735</u>	Modem No.	Detail of Old Modem/SIM	Detail of New Modem/SIM
Meter Capacity	<u>- 15A</u>	<u>- 15A</u>	SIM No.		
Line CT Ratio	<u>20/5A</u>	<u>20/5A</u>			
Line PT Ratio	<u>11 KV 110V</u>	<u>11 KV 110V</u>			
Meter CT Ratio					
Meter PT Ratio					
MP	<u>04</u>	<u>04</u>	Modem cable Type	Optical /Rx Tx/RJ11	Optical /Rx Tx/RJ11
Reading				Old Seal	New Seal
Time			Modem Body		
Date	<u>08/05/23</u>	<u>08/05/23</u>	Modem SIM		
KWHC(Import)	<u>124</u>	<u>109</u>	Seal	<u>Y066440/454</u>	<u>Y066439/494</u>
KWHC(Export)	<u>63</u>	<u>63</u>	Meter Body	<u>14317283</u>	<u>14317246/248</u>
KVARH(Leg)	<u>50</u>	<u>40</u>		<u>14317285</u>	<u>RKE075962</u>
KVARH(Lead)	<u>28</u>	<u>21</u>		<u>RKE075961</u>	
KVAH <u>3mr 154 Ex-86</u>		<u>3mr 132-8x06</u>		<u>RKE075963</u>	<u>RKE075969</u>
KAVUC				<u>RKE075964</u>	<u>RKE075970</u>
KAVUHI			Meter T.P.		
KAVCMD	<u>135</u>	<u>166</u>			
RC	<u>14</u>	<u>14</u>			
P.F.	<u>0.997</u>	<u>0.998</u>	Meter Box	<u>RKE075965</u>	<u>RKE075971</u>
HZ	<u>49.96</u>	<u>49.98</u>		<u>RKE075966</u>	<u>RKE075972</u>
V1	<u>6184.5</u>	<u>6130.2</u>			
V2	<u>6122.7</u>	<u>6106.2</u>	CT/PT/Chamber	<u>RKE075967</u>	<u>RKE075973</u>
V3	<u>6157.4</u>	<u>6122.7</u>		<u>RKE075968</u>	<u>RKE075974</u>
I1	<u>1.731</u>	<u>1.766</u>			
I2	<u>1.575</u>	<u>1.573</u>	MRI Reading Port		
I3	<u>1.701</u>	<u>1.659</u>	Lock No.		
KWH CO	<u>56</u>	<u>56</u>	Continuity / Paper		
C1	<u>50</u>	<u>51</u>	Seal No.		
C2	<u>16</u>	<u>01</u>	Seal Status		
C3	<u>00</u>	<u>00</u>			
C4					
KWH CO(Export)	<u>44</u>	<u>44</u>	Remark :		
C1	<u>18</u>	<u>18</u>			
C2	<u>00</u>	<u>00</u>			
C3	<u>00</u>	<u>00</u>			
C4					
KVAH CO	<u>76</u>	<u>76</u>			
C1	<u>55</u>	<u>55</u>			
C2	<u>22</u>	<u>01</u>			
C3	<u>00</u>	<u>00</u>			
C4					
KVAH CO(Export)	<u>65</u>	<u>65</u>			
C1	<u>20</u>	<u>20</u>			
C2	<u>00</u>	<u>00</u>			
C3	<u>00</u>	<u>00</u>			
C4					
TAMPER	<u>1</u>	<u>1</u>			
Meter Location:- Inside/Outside					
Remarks : Consumer is responsible for all seals/P.S./Locks etc. as per Indian Electricity Act. 2003					
Consumer/Rep.	JE(T)	JE(D)	AE(T)	SDO(D)	EE(T)
					EE(D)

Registrar  
Quantum University